

### Reliable wax-filled thermostat

- · Adjustable set point within temperature range
- Easy installation and serviceability
- · Dirt and lime resistant
- 1/2" Copper & 1/2" NPT tailpiece connection
- Check valves on supply inlets
- · Factory assembled and tested
- · Universal mounting capability
- Lead-free design †
- Thermoplastic polymer cartridge
- · Optional mounting bracket

## **Valve Specifications**

Maximum Operating Pressure 125 PSI (860 kPA)

**Maximum Inlet Temperature** 180° F (82° C)

**Temperature Range** 


Std. 95° F (35° C) to 125° F (52° C)

Temperature Differential - Hot to Mix

10° F (5.6° C)

#### Flow Capacities - GPM (L/Min)

| Model    | Min.<br>Flow | Pressure Drop – PSI (Bar) |               |               |               |               |               |               |
|----------|--------------|---------------------------|---------------|---------------|---------------|---------------|---------------|---------------|
|          |              | 5<br>(.5)                 | 10<br>(1.0)   | 15<br>(1.5)   | 20<br>(2.0)   | 30<br>(2.5)   | 45<br>(3.0)   | 60<br>(4.0)   |
| S59-4007 | 0.5<br>(2.0) | 2.5<br>(11.5)             | 3.5<br>(16.0) | 4.5<br>(20.0) | 5.0<br>(23.0) | 6.0<br>(25.5) | 7.5<br>(28.0) | 8.5<br>(32.0) |



| Models (Must select one) |  |  |  |  |
|--------------------------|--|--|--|--|
| Model Description        |  |  |  |  |
| □ S59-4007               | Navigator® Thermostatic Mixing Valve with 1/2" male NPT connection |  |  |  |
| □ S45-2976               | Optional Mounting Bracket  |  |  |  |

## **Code Compliance and Certifications**

ASSE 1070 & cUPC certified. Complies with California Lead Plumbing Law.








† Wetted surface area contains less than .25% lead.


**/** 

Standard product selections contained within this document are third party CERTIFIED to NSF/ANSI 372 meeting the Lead-Free content requirement. Any product configured with custom options will be COMPLIANT with NSF/ANSI 372 meeting the Lead-Free content requirement.


# Dimensions



Page 1 of 1 2/13/2018
This information is subject to change without notice.
Bradley\_TMV\_PointOfUse\_S59-4007



Engineer's Approval



P.O. Box 309, Menomonee Falls, WI 53052-0309 800 BRADLEY (800 272 3539) +1 262 251 6000 bradleycorp.com